



Site Meeting Notes

Meeting Date: 12/06/17

Subject: Rancho Canada ES Meeting Notes

Meeting Location: Rancho Canada ES

Project: SVUSD Facilities Master Plan 2019

PBK Project No.: 17331

Site:

- Ball wall needs to be repaired or replaced
- Field does not drain properly/floods
- One baseball field can be removed and repurposed
- Wayfinding needs to be added campus-wide
- Add security alarm for campus
- Improve exterior site lighting
- Add emergency lighting
- Remedy current flooding from street
- Add parking spaces
- Concrete lifting in patio/courtyard area
- Kindergarten playground needs a larger canopy
- Dead tree needs to be removed
- Existing drain cover at Northwest corner is not secured
- Remedy flooding in parking lots and at portable classrooms
- Roof leaks in Rooms 4, 12, 15, and 24
- Wall is cracking at Room K-1
- Rooms 10 and 11 door frames are coming off
- Rooms 3 and 4 have water infiltration at doors and windows
- Sinks in classrooms don't drain well
- The steps at Room 25 are eroding and the wood is rotted-out
- Lunch service line canopy needs to be repaired or replaced
- Lunch tables need to be replaced
- Storage bins need to be replaced
- Install permanent soccer goals
- Replace wood chips at playground with rubber surface
- Replace some tetherball courts with handball courts
- Update baseball field benches
- Install permanent lunch shelter

Next Generation Classroom:

- Would like 21st Century furniture
- Use unused classrooms for support spaces like Innovation Labs or Maker Spaces

Technology:

- Teachers need new laptops
- Need more technology in the classrooms – specifically upgrading projectors or installing something like smart boards

Support Space:

- Administration space needs security gate between waiting area and offices
- Roof leaks over Principal's conference room
- Need new phones in teachers' work rooms
- Roof leaks in MPR
- Repair or replace shelving in library
- More copiers are needed on campus