



# Site Meeting Notes

**Meeting Date:** 11/16/17

**Subject:** Los Alisos IS Meeting Notes

**Meeting Location:** Los Alisos IS

**Project:** SVUSD Facilities Master Plan 2019

**PBK Project No.:** 17331

## Site:

- The building is not adequately lit
- Repair or replace HVAC for portables
- The exhaust air systems do not perform adequately, the portables have odor issues (water gets trapped under building) and the Restrooms have exhaust issues
- The circuit breakers trip frequently in the center work area
- The heating system in Rooms C5 & C6 do not work and you cannot adjust the thermostat
- The gym room has a few leaks
- Painting could be redone
- Better placement of outlets throughout campus
- Bleachers need more space
- Signage
- Number of security cameras
- Alarmed Rooms (portables, band)
- Cracks in ground and cement
- Rainfall/Puddles/Gutters
- Shade Structure

## Next Generation Classroom:

- STEM classrooms needs laptops

## Technology:

- Computers are too old, needs to be replaced

## Support Space:

- Backboards, nets, rims, and posts can be improved – neighborhood church uses this area
- Library/Media Center
  - Improve space to facilitate staff meetings with flexible seating and charging stations
  - Intervention class in library
  - New outlets in the Lecture Room